



December 11, 2016

Reference: 5216-20

To
Moti Ben-Zur
Q.A. Manager
Raphael Valves Industries Ltd

Re: **Approval for use in Valves and Filters**

Based on the SII test certificate no. 9412221482, 9512233480 and 9612228777 for complying with the requirements of SI 5452 (2012)

In accordance with the procedures of the Ministry of Health and after testing representative samples of the products, we have no objection for the use of the products family listed below made of cast iron body coated with polyamide or polyester and with EPDM sealing component, manufactured by "Raphael Valves Industries Ltd", for use at drinking water application with diameters of 2" and above, in temperature up to 40°C.

This approval refer to the following models:

Gate Valves: TRL, TMS, TRS
Butterfly Valves: B7G, B13, B3, BTF, BHF, BJF
Hydraulic Valves: RAY, RAF, G
Non-return Valves: E-51, OSW-51, S-51
Line Filters: V-251

Any change in the product or its composition requires further examination and re-approval.

This letter does not constitute a recommendation to use said products, and should not be used for publication in the mass media.

This certificate is valid until Oct. 24, 2017.

Sincerely,

Naor Cohen
Head of Water Section

This approval will be published in the certified products Bank for drinking water, which is updated each quarter