

CERTIFICATE OF COMPLIANCE

Certificate Number 20160617-EX26941
Report Reference EX26941-20160616
Issue Date 2016-JUNE-17

Issued to: RAPHAEL VALVES INDUSTRIES (1975) LTD
N INDUSTRIAL ZONE
PO BOX 555
30600 OR-AQIVA ISRAEL

This is to certify that representative samples of SPECIAL SYSTEM WATER CONTROL VALVES, DELUGE TYPE
See Addendum

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 260, Standard for Dry Pipe and Deluge Valves for Fire Protection Service
ULC-ORD-C260-1975, Guide for the Investigation of Dry Pipe, Deluge, and Pre-Action Valves for Fire Protection Service

Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20160617-EX26941
Report Reference EX26941-20160616
Issue Date 2016-JUNE-17

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

FDV-DE0 –Electrical Actuated with Local Reset Deluge Valve and FDV-DH0 – Hydraulic Actuated with Local Reset Deluge Valve in 1.5, 2, 2.5, 3, 4, 6 and 8 in. sizes, for vertical installation for pressures not exceeding 250 psig (1730 kPa) as shown in the manufacturer's installation instructions.

MFDV-AH1 –Hydraulic Actuated with Remote Reset Deluge Valve, FDV-DE1 –Electrical Actuated with Remote Reset Deluge Valve and FDV-DH1 – Hydraulic Actuated with Remote Reset Deluge Valve in 1.5, 2, 2.5, 3, 4, 6 and 8 in. sizes, for vertical installation for pressures not exceeding 250 psig (1730 kPa) as shown in the manufacturer's installation instructions.

FDV-DP1 – Pneumatic Actuated with Remote Reset Deluge Valve and FDV-AP1 –Pneumatic Actuated with Remote Reset Deluge Valve in 1.5, 2, 2.5, 3, 4, 6 and 8 in. sizes, for vertical installation for pressures not exceeding 250 psig (1730 kPa) as shown in the manufacturer's installation instructions.

FDV-DC0 – Pneu-Electric Actuated with Local Reset Deluge Valve, FDV-AC1 –Pneu-Electric Actuated with Remote Reset Deluge Valve and FDV-DC1 – Pneu-Electric Actuated with Remote Reset Deluge Valve in 1.5, 2, 2.5, 3, 4, 6 and 8 in. sizes, for vertical installation for pressures not exceeding 250 psig (1730 kPa) as shown in the manufacturer's installation instructions.

FDV-DA1 – Hydraulic actuated & Anti-Columning Remote Reset Deluge Valve in 1.5, 2, 2.5, 3, 4, 6 and 8 in. sizes, for vertical installation for pressures not exceeding 250 psig (1730 kPa) as shown in the manufacturer's installation instructions.

FDV-PE0–Electrical Actuated with Local Reset, Pressure reducing Deluge Valve and FDV-PH0 – Hydraulic Actuated with Local Reset, Pressure reducing Deluge Valve in 1.5, 2, 2.5, 3, 4, 6 and 8 in. sizes, for horizontal installation for pressures not exceeding 250 psig (1730 kPa) as shown in the manufacturer's installation instructions.

FDV-PH1 –Hydraulic Actuated with Remote Reset, Pressure reducing Deluge Valve in 1.5, 2, 2.5, 3, 4, 6 and 8 in. sizes, for horizontal installation for pressures not exceeding 250 psig (1730 kPa) as shown in the manufacturer's installation instructions.

FDV-PP0 –Pneumatic Actuated with Local Reset, Pressure reducing Deluge Valve and FDV-PP1 – Pneumatic Actuated with Remote Reset, Pressure reducing Deluge Valve in 1.5, 2, 2.5, 3, 4, 6 and 8 in. sizes, for horizontal installation for pressures not exceeding 250 psig (1730 kPa) as shown in the manufacturer's installation instructions.

FDV-PC0 – Pneu-Electric Actuated with Local reset, Pressure reducing Deluge Valve and FDV-PC1 – Pneu-Electric Actuated with Remote Reset, Pressure reducing Deluge Valve in 1.5, 2, 2.5, 3, 4, 6 and 8 in. sizes, for horizontal installation for pressures not exceeding 250 psig (1730 kPa) as shown in the manufacturer's installation instructions.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20160617-EX26941
Report Reference EX26941-20160616
Issue Date 2016-JUNE-17

FDV-PA0 – Hydraulic actuated with Pressure reducing Local Reset Deluge Valve & Anti-Columning and FDV-PA1 – Hydraulic actuated with Pressure reducing Remote Reset Deluge Valve with Anti-Columning in 1.5, 2, 2.5, 3, 4, 6 and 8 in. sizes, for horizontal installation for pressures not exceeding 250 psig (1730 kPa) as shown in the manufacturer's installation instructions.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

