



January 4, 2024
Reference: 522340

To
Katherine Guryev
Q.A. Manager
Raphael Valves Industries Ltd

Re: **Product approval for use with drinking water**
Based on SII test certificates no. 7112212981/1 for complying
with the requirements of SI 5452 (2016)

In accordance with the instructions of the Israeli Ministry of Health and after testing representative samples of the product and receiving a relevant information about it, we have no objection to the use of hydraulic valves type "RAF" and "G", made by "Raphael Valves Industries Ltd", Israel, for use in drinking water applications up to 40°C.

Any modification of the product or its composition requires further examination and re-approval.

This letter does not constitute a recommendation to use the mentioned product and should not be published in the mass media.

This approval is valid until May 25, 2027.

Sincerely,
Assaf Amram
Head of water section
Chemistry, Food and Water Branch

This document is not approval for marking the product with the Standards Mark

The information in this approval will be published in "search engine drinking water SI 5452"
on the SII site